



322/1028/163/2019

Gdańsk, 29-04-2019

HYGIENIC CERTIFICATE No 161/322/163/2019

- 1. Name of product (material)** Particleboard P2 - ClassicBoard P2
PN-EN 312
thickness ranges: 6,0 ÷ 40,0 mm
- 2. Application** furniture production and interior's decorate
- 3. Applicant institution** Pfleiderer Polska Spółka z o.o.
Strzegomska 42AB St.
PL-53-611 Wrocław
- 4. Manufacturer** Pfleiderer Grajewo Spółka z o.o.
Wiórowa 1 St.
PL-19-203 Grajewo
- 5. The product meets the requirements of hygiene on the following conditions:**
 - the load the material amounts 0,6 m²/m³ in relation to the cubage of residential premises, premises intended for permanent stay of patients in health service buildings, children and young people in school buildings and of premises intended for storing food products – hereinafter referred as to the “places of A category”,
 - load the material amounts 1,2 m²/m³ the cubage of premises in public buildings other than those listed above and auxiliary premises in apartments - hereinafter referred as to the “places of B category” according to the Regulation of Minister of Health and Social Care dated on 12th March of 1996.

The certificate does not concern working conditions and occupational hygiene during the assembly of product. Facilities that use the product should be ventilated until the odour disappears.
- 6. Basis of certificate:** applications of OB-RPPD sp. z o.o. BW/452/452/19 dated April 16, 2019, test report number 8299/12/2019 dated April 15, 2019 issued by Research & Development Centre for Wood - Based Panels in Czarna Woda.
Hygienic Class E1.
- 7. The present certificate shall be changed or voided if either party presents sufficient evidence.**
Hereby attest will expire 5 years after issuing date or if any changes either in composition or manufacturing technology of the product have been introduced.

KIEROWNIK
Zakładu Toksykologii Środowiska
Lidia Wolska
prof. dr hab. Lidia Wolska